

E-PDD Addressable Duct Detector Substitution - Update

Preface

This is an update to a previous bulletin regarding the availability of the E-PDD.

Issue

Due to a manufacturing issue, Edwards was unable to deliver E-PDD addressable duct detectors used with the E-FSA64 and E-FSA250 fire alarm panels.

Solution

The manufacturing issue has been resolved and an addressable duct detector is once again available. The detector will now be sold under the part number *FX-PDD*, and is identical in appearance and function to the previous E-PDD part number. The FX-PDD is compatible with all E-FSA addressable fire alarm panels, can be used on any new or existing installations, and uses the same SD-T* sampling tubes and SD-TRK test stations.

Conclusion

Going forward, any jobs requiring an addressable duct detector for the E-FSA fire alarm system should now use the FX-PDD part number. Orders received for the older E-PDD duct detector will automatically be switched to the FX-PDD.

Contact information

Please contact your local Sales Manager or Manufacturer's Representative for any questions you may have.